



**FIGURE 1. MULTI-METER BANKS-(LIMITED TO 6 METERS MAX.)**  
DUCTS IN FLOOR OR EITHER SIDE OF CABLE COMPARTMENT.

SWITCH CAPACITY	A (MIN)	B (MIN)	C (MIN)	D	COMMENTS
0-400	12"	11"	LIMITED BY HGT. OF METER & DUCTS	3"	3-1/2" KNOCKOUT IN BOTTOM
401-800	15"	VARIES WITH WIDTH OF LUG PADS		3"	FULL OPENING IN BOTTOM OF CABLE COMPARTMENT
801-1200	18"		SEE NOTE 1	3"	
AMPERES					

**NOTES:**

- WHEN LIMITER LUGS ARE SPECIFIED, ADDITIONAL SPACE IS REQUIRED. IN THOSE CASES "A" MUST BE INCREASED TO 36" INCHES. THIS CAN BE ACCOMPLISHED BY USING AN 18 INCH TROUGH ("C"), IF CABLE COMPARTMENT IS DIRECTLY ABOVE THE INCOMING DUCTS. IF OFFSET AS IN THE ALTERNATE LOCATION, ("C") NEED ONLY COVER DUCTS.
- SAME DIMENSIONS FOR TOP CONNECTED EQUIPMENT, EXCEPT LANDINGS FOR LUGS WILL BE ROTATED 180° AND NEUTRAL BUS PLACED IN TOP POSITION.
- CABLE MAY CROSS THE BUS BARS PROVIDED THE BUS BARS OR THE LUG LANDING PADS ARE STAGGERED AND PROVISION MADE SO THAT THERE IS NO POSSIBILITY OF THE SERVICE CABLES MAKING CONTACT WITH THE BUS BARS CROSSED.

REFERENCES	ITEMS COVERED	NOTES
	CLEARANCES FOR CABLE TERMINATIONS IN MULTI-METER BANKS.	

REV.	CHANGE	APP'D	TITLE	CABLE TERMINATIONS	PREP.	DATE	01/28/82	DESIGN NO.
			CUSTOMER DESIGN			BY	W.L.B.	CD.005.01
					APPROVED			SHT. NO. 1 OF 11
					J.D.S.G.L.K			