



FIGURE 2. MULTI-METER BANKS (LIMITED TO 6 METERS MAX.) DUCTS IN WALL DIRECTLY BELOW CABLE COMPARTMENT.

SWITCH CAPACITY	A (MIN)	B (MIN)	C (MIN)	D (MIN)	COMMENTS
0-400	12"	11"	LIMITED BY HGT. OF METER OR NUMBER OF DUCTS & DIMENSION "D"	3"	TROUGH TO COVER DUCTS & FULL OPENING IN BOTTOM OF CABLE COMPARTMENT
401-800	15"	VARIES WITH WIDTH OF LUG PAD		3"	
801-1200 AMPERS	18"			CONTACT PEPCO. 18" WHEN LIMITER LUGS ARE SPECIFIED.	

NOTES

1. SAME DIMENSIONS FOR TOP CONNECTED EQUIPMENT, EXCEPT LANDINGS FOR LUGS WILL BE ROTATED 180° AND NEUTRAL BUS PLACED IN TOP POSITION.
2. CABLES MAY CROSS THE BUS BARS PROVIDED THE BUS BARS OR THE LUG LANDING PADS ARE STAGGERED AND PROVISION MADE SO THAT THERE IS NO POSSIBILITY OF THE SERVICE CABLES MAKING CONTACT WITH THE BUS BARS CROSSED.

REFERENCES	ITEMS COVERED	NOTES
	CLEARANCES FOR CABLE TERMINATIONS IN MULTI-METER BANKS.	

REV.	CHANGE	APP'D	TITLE	CABLE TERMINATIONS	PREP.	DATE	01/22/82	DESIGN NO.
			CUSTOMER DESIGN			BY	W.L.B.	CD.005.02
					APPROVED			SHT. NO. 2 OF 11
					J.D.S.	G.L.K.		