



FIGURE 3. MAINLINE SWITCH-400 AMPERES.

- NOTE: 1. 500 KCMIL COPPER OR ALUMINUM CABLE LARGEST SIZE.
2. NEUTRAL TERMINALS TO HAVE SAME DRILLINGS AND CLEARANCES AS PHASE TERMINALS.

REFERENCES			ITEMS COVERED			NOTES		
			CLEARANCES FOR CABLE TERMINATIONS IN MAINLINE SERVICE DISCONNECT SWITCHES-400 AMPERE CAPACITY					
REV.	CHANGE	APP'D	TITLE	CABLE TERMINATIONS	PREP.	DATE	01/19/82	DESIGN NO.
				CUSTOMER DESIGN		BY	W.L.B.	CD.005.03
					APPROVED			SHT. NO. 3 OF 11
					J.D.	G.L.K.		