



FIGURE 4.

MAINLINE SERVICE SWITCH-TOP CONNECTED.
REFER TO FIG. 5 SHT. 5 FOR SERVICE DUCTS ABOVE SWITCH.

SWITCH SIZE	A	B	TROUGH SIZE
401-800A	15"	12"	COVER INCOMING CONDUIT & FULL OPENING IN TOP OF SW. SUBMIT DRAWINGS TO PEPCO
801-1199A	SEE NOTE 1	*FULL OPENING IN TOP OF SW.	
1200-ABOVE	18"		

- NOTES:
- CONTACT PEPCO-15" WITHOUT LIMITER LUGS, 18" WITH LIMITER LUGS.
 - CABLE SUPPORTS SHALL BE 1" OR LARGER NON-FERROUS, NON-HYGROSCOPIC AND FIRE RETARDANT MATERIAL SUCH AS EXTREN 525 FIBERGLASS TUBING, BENELEX BAR, GLASTIC CHANNEL OR MICARTA.

REFERENCES			ITEMS COVERED			NOTES		
			CLEARANCES FOR CABLE TERMINATIONS IN MAINLINE SERVICE DISCONNECT SWITCHES. TOP CONNECTED			2. NEUTRAL TERMINALS TO HAVE SAME DRILLINGS AND CLEARANCES AS PHASE TERMINALS.		
REV.	CHANGE	APP'D	TITLE	CABLE TERMINATIONS	PREP.	DATE	01/11/81	DESIGN NO.
			CUSTOMER DESIGN			BY	W.L.B.	CD.005.04
					APPROVED			SHT. NO. 4 OF 11
					J.D.	S.G.L.	K.	