



NOTES:

1. C = RDWY.----- 21"
FLUSH SDWK.----- 6"
RECESSED SIDEWALK 18"
2. JOB INSTRUCTIONS WILL DIRECT WHICH ROOF IS TO BE USED
3. ASSEMBLY STOCK #P000-2172
THIS DWG. SUPERSEDES
DWG. 6-1-684 DATED 9-7-59
4. INSTALL SUMP PUMP PIT, GROUND ROD AND GUTTER IN MANHOLE PER DWG.'S 4-2-1096 AND 4-2-1060. FOR TRANSFORMER MANHOLES INSTALL SUMP PUMP PIT ON L.V. END OF MANHOLE.
5. REV Z: OBSOLETE DRAWING ON APPROVAL DATE

CONCRETE SCHEDULE	
FLOOR	9 CU.FT
WALLS	16 CU.FT.PER.VERT.FT

COMPATIBLE UNIT DESIGNATION:MH0404MY

DRAWN: AIPL | DVLPED: CPC | DATE: 10/16/78 | REVIEWED: TWM | DATE: 12/08/05 | APPRVD: RCW | DATE: 12-21-05 | OBSOLETE | REV: Z



DISTRIBUTION
STANDARDS

4' - 0" X 4' - 0" MANHOLE