





A




B



C




D




E




F



G




H




I




J



K



L



M

TABLE OF APPROXIMATE CUBIC YARDS OF CONCRETE FOR 100 FEET OF CONDUIT WITH 3 INCHES OF CONCRETE ENVELOPE ON TOP AND THE BASE, AND 2 INCHES OF CONCRETE ON BOTH SIDES WITH 1½ INCHES SEPARATION OF DUCT.

DUCT FORMATION	NO. OF DUCTS	SIZE OF DUCTS			
		3"	4"	5"	6"
			6" C/C	7" C/C	8" C/C
A	1	1.6	1.9	2.2	3.2
B	2	2.6	3.1	3.6	5.2
C	4		4.5	5.3	7.4
D	6		5.9	7.0	9.6
E	8		7.4	8.7	11.8
F	3		4.3	5.1	7.0
G	6		6.2	7.4	10.0
H	9		8.2	9.7	13.2
I	12		10.1	12.0	16.2
J	4		5.5	6.5	9.0
K	8		8.0	9.4	12.8
L	12		10.4	12.4	16.6
M	16		12.9	15.4	20.4

NOTE:  
REV A: CHANGED DWG FORMAT.

DRAWN: DPJ | DVLPEP: FM | DATE: 07-01-84 | REVIEWED: RDS | DATE: 08/26/15 | APPRVD: AAT | DATE: 08/26/15 | NEXT REVIEW: 08/19 | REV: A



POWER  
DISTRIBUTION  
STANDARDS

PVC & FIBERGLASS CONCRETE  
ENCASEMENT