



## Approved Residential Meter Sockets for Use in Pepco Service Territory

### Introduction:

- All meter sockets must have an affixed Pepco warning label.
- Meter sockets without an affixed Pepco warning label will not be placed in service.
- Customers may purchase meter sockets from local distributors.

### Approved Residential Meter Sockets:

<u>Material Description</u>	<u>Manufacturer Name</u>	<u>Part Number</u>
Socket Stud Type 1 PH 3W 200A 600V	Durham Line	1007448A
Socket Stud Type 1 PH 3W 200A 600V	Milbank Mfg.	S1619-XL
Socket Stud Type 1 PH 3W 320A 600V	Durham Line	1007801
Socket Stud Type 1 PH 3W 320A 600V	Milbank Mfg.	U5161-X

In addition to purchasing metering equipment from local distributors, customers may also continue to purchase their 200A and 320A metering equipment from Pepco. If this option is chosen, contact your Distribution Engineering representative to obtain a requisition number. You can then contact Pepco's Stores Department at **(202) 388-2458** to make arrangements at least 24 hours before the material is required to assure its availability.

